

CE CERTIFICATE

Notified Body No. 0370

No. **0370-CPR-0359**

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation (EU) Nr. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

SMOKE AND HEAT CONTROL SYSTEMS. FANS.

RANGE: **CVHT F400**

Placed on the market under the name of:

S&P SISTEMAS DE VENTILACIÓN, S.L.U.

C/ LLEVANT, 4
08150 PARETS DEL VALLÈS (BARCELONA)

And produced in the manufacturing plant:

21/32306384 (EUROPE)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-3:2015

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**.

This certificate was first issued on 25th November 2005 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. It is confirmed on 22nd December 2021.

The monitoring assessment will be done before 30th November 2022

Bellaterra, 22nd December 2021




LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate into our website at: www.appluslaboratories.com/certified_products

0370-CPR-0359

Annex according to **EN 12101-3:2015**

SMOKE AND HEAT CONTROL SYSTEMS. PART 3: SPECIFICATION FOR POWERED SMOKE AND HEAT CONTROL VENTILATORS (FANS)

CERTIFIED PERFORMANCE

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Response delay - Opening under wind load within a given time; - Opening under snow load within a given time.	4.1.1	NA
		NA
Operational reliability - Application categories; - Motor rating.	4.2.2	<ul style="list-style-type: none"> • Thermally uninsulated • For use outside smoke reservoir • Horizontal direction of motor shaft • Direct feed • Dual purpose use
	4.2.3	NPD
Effectiveness of smoke/hot gas extraction: - Gas flow and pressure maintenance during smoke and heat extraction test.	4.3.2	+/-20% (P _s)
Resistance to fire	4.4	F ₄₀₀ (120)
Ability to open under environmental conditions - Opening under wind load within a given time; - Opening under snow load within a given time.	4.5	NA
		NA
Durability of operational reliability	4.6	NPD

PASS; NPD = No Performance Determined; NA = Not Applicable

PRODUCT

1.- Application:

- Extractor tested outside the furnace.
- Extractor F400 (120).
- Dual use.
- Fans with vertical airflow inlet and horizontal and vertical airflow outlet.
- Type H models are models with horizontal air discharge.
- Type V models are models with vertical air discharge.

2.- Characteristics:

- Motor: Three Phase and Single Phase motors, standard type by WEG and ABB.
- Rated frequency: 50 Hz
- Rated Voltage motor: 400 V

3.- Accessories:

- PER-CN
- PER-CR
- ACOP RECT F400
- PAVZ
- CVD
- CHTI

The complete technical data of the certified range **CVHT F400** are detailed in the technical file and the range report nº 17/13774-2349 and 20/21609-8 M1.