

Declaration of Performance (DoP)
(According to regulation EU no 305/2011)

No-TE-77/19
(Performance System 3)



1. Product Name:	Flexible duct "Izotex A21 Antimicrobial"
2. Mode – Type Name:	Izotex A21 Antimicrobial dia. 082, Izotex A21 Antimicrobial dia. 102, Izotex A21 Antimicrobial dia. 112, Izotex A21 Antimicrobial dia. 120, Izotex A21 Antimicrobial dia. 127, Izotex A21 Antimicrobial dia. 133, Izotex A21 Antimicrobial dia. 140, Izotex A21 Antimicrobial dia. 152, Izotex A21 Antimicrobial dia. 160, Izotex A21 Antimicrobial dia. 165, Izotex A21 Antimicrobial dia. 185, Izotex A21 Antimicrobial dia. 203, Izotex A21 Antimicrobial dia. 229, Izotex A21 Antimicrobial dia. 254, Izotex A21 Antimicrobial dia. 280, Izotex A21 Antimicrobial dia. 305, Izotex A21 Antimicrobial dia. 315, Izotex A21 Antimicrobial dia. 356, Izotex A21 Antimicrobial dia. 406, Izotex A21 Antimicrobial dia. 457, Izotex A21 Antimicrobial dia. 508,
3. Manufacturer	TEHNOEXPORT doo Jovana Popovica 43, 22320 Indjija, Serbia Tel: +381(0) 22 553 453 E-mail: office@tehnoexport.co.rs Web site: www.tehnoexport.rs
4. Applicable Regulation:	Construction products No 305/2011
5. Evaluated acc. to:	NF P92-507, (February 2004) , Fire safety - Building - Interior fitting materials - Classification according to their reaction to fire - Sécurité contre l'incendie NF P92-503 (December 1995) , Safety against fire. Building materials. Reaction to fire tests. Electrical burner test used for flexible materials. - Sécurité contre l'incendie
6. Test Report No. :	P195335 – DEC/3

Flexible duct "Izotex A21 Antimicrobial" is according to French NF standard, classified as M1

Indjija, date: 2019-12-18
Branislav Petkovic
Name of signee

