

Declaration of Performance (DoP)

(According to regulation EU no 305/2011)

No-TE-78/19
(Performance System 3)



1. Product Name:	Flexible duct "Izotex A21 Antimicrobial"
2. Mode – Type Name:	Izotex A21 Antimicrobial dia. 082, Izotex A21 Antimicrobial dia. 102, Izotex A21 Antimicrobial dia. 112, Izotex A21 Antimicrobial dia. 120, Izotex A21 Antimicrobial dia. 127, Izotex A21 Antimicrobial dia. 133, Izotex A21 Antimicrobial dia. 140, Izotex A21 Antimicrobial dia. 152, Izotex A21 Antimicrobial dia. 160, Izotex A21 Antimicrobial dia. 165, Izotex A21 Antimicrobial dia. 185, Izotex A21 Antimicrobial dia. 203, Izotex A21 Antimicrobial dia. 229, Izotex A21 Antimicrobial dia. 254, Izotex A21 Antimicrobial dia. 280, Izotex A21 Antimicrobial dia. 305, Izotex A21 Antimicrobial dia. 315, Izotex A21 Antimicrobial dia. 356, Izotex A21 Antimicrobial dia. 406, Izotex A21 Antimicrobial dia. 457, Izotex A21 Antimicrobial dia. 508.
3. Manufacturer	TEHNOEXPORT doo Jovana Popovica 43, 22320 Indjija, Serbia Tel: +381(0) 22 553 453 E-mail: office@tehnoexport.co.rs Web site: www.tehnoexport.rs
4. Applicable Regulation:	Construction products No 305/2011
5. Evaluated acc. to:	EN 13501-1:2007+A1:2009
6. Test Report No. :	Report No. 1871 – CPR – RtF -337/10.12.2019 for classification of reaction to fire performance in accordance with EN 13501-1:2007 + A1:2009 – CTEC Ltd – Notified Body No. 1871

The Format of the reaction to fire classification for linear pipe thermal insulation products is:

Fire Behavior		Smoke production			Flaming Droplets	
B _L		s	1	,	d	0

Reaction to fire classification of construction products:

B_L-s1, d0

Indjija, date: 2019-12-18

Branislav Petkovic

Name of signee

