

# **GSH** **Güteschutzgemeinschaft** **Hartschaum e.V.**

## **Certificate of Constancy of Performance**

**0919-CPR-817-FEF-R3.e**

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the

**construction products as listed in Annex 1 of this certificate**

produced by

**Armacell GmbH**  
**Robert-Bosch-Straße 10**  
**D-48153 Münster**

in the manufacturing plant

**Armacell Yalitim A.S.**  
**Barakfakih S.B. 16 Cadde No. 13**  
**16450 Kestel/Bursa**  
**Turkey**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

**EN 14304:2009+A1:2013**


under system 1 are applied and that

**the products fulfil all the prescribed requirements set out above.**


This certificate was first issued on 17.03.2023 and will remain valid until **31.03.2024** as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

The validity can be prolonged by the GSH certification body, at latest until 31.03.2026

Celle, 17.03.2023



Corth Siegfried  
Manager of the certification body



Schildenstraße 24  
D-29221 Celle  
Notified Body 0919  
ÜZ: UG 049



Tel +49 (0)5141-88 92 65  
Fax +49 (0)5141-88 92 67  
[www.gsh.eu](http://www.gsh.eu)  
[info@gsh.eu](mailto:info@gsh.eu)





# GSH Güteschutzgemeinschaft Hartschaum e.V.

## Annex 1 of the CERTIFICATE No. 0919-CPR-817-FEF-R3.e

Table 1: Product description:


Product name	Description	Thermal conductivity $\lambda_D$ at 0 °C W/mK	Reaction to fire Euroclass	Maximum service temp. (ST(+)) °C	Minimum service temp. (ST(-)) °C	Water vapour resistance factor (MU)	Soluble ions/pH (CL)	Designation code of manufacturer
<b>Oneflex</b> Tubes (6-32 mm) Sheets (3-50 mm)	Elastomeric sheets, tubes and tape	0,035	B <sub>1</sub> -s3, d0 B-s3, d0	110	-50	5.000		FEF - EN14304 - ST(+)110 – ST(-)50 - MU 5000
<b>Vidoflex</b> Tubes (6-32 mm) Sheets (3-50 mm)	Elastomeric sheets, tubes and tape	0,035	B <sub>1</sub> -s3, d0 B-s3, d0	110	-50	5.000		FEF - EN14304 - ST(+)110 – ST(-)50 - MU 5000
<b>Armaflex XG</b> Sheets (3-25 mm) Sheets (32 mm)	Elastomeric sheets and tape	0,035 0,036	B-s3, d0 B-s3, d0	110	-50	10.000 7.000		FEF - EN14304 - ST(+)110 – ST(-)50 - MU 10000 FEF - EN14304 - ST(+)110 – ST(-)50 - MU 7000

This Annex is valid until 31.03.2024. The validity can be prolonged by the GSH certification body.

Celle, 17.03.2023

  
Corth Siegfried

Manager of the Certification Body



Schildenstraße 24  
D-29221 Celle  
Notified Body 0919  
ÜZ: ÜG 049

Tel +49 (0)5141-88 92 65  
Fax +49 (0)5141-88 92 67  
www.gsh.eu  
info@gsh.eu

