



UK Declaration of conformity (DoC)

The manufacturer S&P Sistemas de Ventilación S.L.U
C/Llevant , 4
08150-Parets del Vallès-Barcelona

declare that the Declaration of Incorporation is issued under our sole responsibility and belongs to the following partly completed machinery:

SINGLE INLET BACKWARD CURVED CENTRIFUGAL FANS

Tipo BSB
Serial number All Manufactured
CE mark date 12

The object of the declaration defined above complies with the requirements set out in the following articles of Appendix I of the supply of Machinery (Safety) Regulations 2008: Articles 1.1.2 and 1.1.5. Additional safety measures are still necessary to protect against risks arising from moving parts as per Article 1.3.8. Therefore the manufacturer of machinery or equipment where the fan is incorporated into or assembled with is responsible for compliance with Article 1.3.8 and 1.4.1. Compliance with EN ISO 13857 refers to guards and protective devices when supplied, and installed, with the product.

It must not be put into service until the machine in which it is incorporated has been declared in conformity with the provisions of the supply of Machinery (Safety) Regulations 2008 according with Annex II-1 part B.

It is also in conformity with the The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012.

The following harmonized standards and technical specifications have been applied:

EN ISO 12100:2010 //EN ISO 12499:2008 //EN ISO 13857:2019 //

It is the responsibility of the user to select a motor and transmission drive system within the limits of the maximum allowable speed, complying also with the Ecodesign for Energy-Related Products and Energy Information (Amendment) (EU Exit) Regulations 2019.

The assembly of the fan, motor and transmission drive system selected above only lacks the necessary protective means or safety components for avoiding the following hazards: contact with a rotating shaft or impeller, object being drawn into the fan inlet and ejected at fan discharge, even when the fan is switched off, and access through an unauthorized opening of connecting ductworks. The manual instructions provides safety measures to ensure the compliance with EN ISO 12499.

We are committed to provide relevant information on this product in response to a reasonable request by national authorities.

The Technical Director is the person authorized to compile relevant technical documentation in accordance with Annex VII part B.



S&P Sistemas de Ventilación S.L.U.

Signed by

A handwritten signature in black ink, appearing to be 'C. Campderrós'.

Carlos Campderrós
S&P Sistemas de Ventilación S.L.U
Octubre 2022