

VERIFICATION OF COMPLIANCE

No.: LVD GZES1612017839HS

Applicant: Holtop International Co., Ltd.
Room 2-1108 Industrial Plaza, Tian An Hi-Tech Ecological Park,
555 Panyudadao North Road, Panyu District, Guangzhou,
Guangdong, China

Manufacturer: Beijing Holtop Air Conditioning Co., Ltd.
Building 1-7, NO.5, NO.7, Guanggu Street, Kangzhuang Town,
Yanqing District, Beijing, China

Product Name: Energy Recovery Ventilator

Model No.: See page 2

Trade Mark: **HOLTOP**

Rating: See page 2

Protection against Electric Shock: Class I

Degree of Protection: IPX2

Additional Information: —

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: EN 60335-1: 2012 + A11
EN 60335-2-80: 2003 + A1 + A2
EN 62233: 2008

as shown in the

Test Report Number(s): GZES161201783901

This Verification of Compliance has been granted to the applicant based on the results of tests, performed by Laboratory of SGS-CSTC Standards Technical Services Co., Ltd. on sample of the above-mentioned product in accordance with the provisions of the relevant harmonized standards under the Low Voltage Directive 2014/35/EU. The CE marking as shown below can be affixed, under the responsibility of the manufacturer, after completion of an EC Declaration of Conformity and compliance with all relevant EC Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

David C. F. 
Senior Techn. Manager
SGS-CSTC



2017-10-18

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)

No.:

LVD GZES1612017839HS

Other information added:

Rating:

Model	Rated current (A)
XHBQ-D1.5DCTP, XHBQ-D1.5DCTPA	0,47 A
XHBQ-D2.5DCTP, XHBQ-D2.5DCTPA	0,71 A
XHBQ-D3.5DCTP, XHBQ-D3.5DCTPA	0,85 A
XHBQ-D5DCTP, XHBQ-D5DCTPA	1,35 A
XHBQ-D6.5DCTP, XHBQ-D6.5DCTPA	1,61 A
XHBQ-D8DCTP, XHBQ-D8DCTPA	2,19 A
XHBQ-D10DCTP, XHBQ-D10DCTPA	2,47 A
XHBQ-D15DCTP, XHBQ-D15DCTPA	4,38 A
XHBQ-D20DCTP, XHBQ-D20DCTPA	4,2 A
XHBQ-D1.5DMTHA, XHBQ-D1.5DMTH	0,45 A
XHBQ-D2.5DMTHA, XHBQ-D2.5DMTH	0,72 A
XHBQ-D3.5DMTHA, XHBQ-D3.5DMTH	1,0 A
XHBQ-D5 DMTHA, XHBQ-D5DMTH	1,34 A
XHBQ-D6.5DMTHA, XHBQ-D6.5DMTH	2,27 A
XHBQ-D8DMTHA, XHBQ-D8DMTH	2,54 A
XHBQ-D10DMTHA, XHBQ-D10DMTH	3,26 A
XHBQ-D13DMTHA, XHBQ-D13DMTH	3,3 A
XHBQ-D15DMTHA, XHBQ-D15DMTH	4,2 A
XHBQ-D20DMTHA, XHBQ-D20DMTH	4,2 A


 David
 Senior Tech.
 SGS-CSTC



2017-10-18

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)